



## Top View

### **End View**

#### Notes:

ASTM C 1613 Compliant 4" Inlet/Outlet (Standard) 4" PVC 90 in Baffle Wall 2/3 - 1/3 Compartment Capacity





Side View

Baffle View

#### **Specifications**

Concrete: 5,000 psi minimum strength (28 day)
Reinforcing: Primary reinforcement will be rebar.
Risers: Grade rings and manhole frames and covers sold separately.
Sealant: Sealant used in the seam of the tank will meet or exceed ASTM C990.
Pipe Penetrations: Inlet and outlets are fitted with seals that meet or exceed all ASTM C923 specifications.
Partition Wall: The partition wall, if present, is poured monolithically.
Drawing: All measurements are accurate within ± 1 inch.

Tank Warranty: See Terms & Conditions.

Centroid(s): Lid (60, 30), Base (64, 30)

**Weights** 

Top - 3,117 lb Bottom - 3,135 lb

**Anti-Float Protection** 

0" of water

Installation: The tank hole is not to be more than 18 in. longer and wider than the tank. There shall be a minimum of 6" of 3/4" stone bedding. Do not install across path of vehicles or heavy equipment. This tank is designed for one hundred fifty pounds per square foot (150 lb/ft2) uniform loading on the top of the tank with a max backfill cover of 36" and a minimum of 6".

# 1,000 Gallon Grit Tank

P.O. Box 370 - Kingston TN 37763 Phone 888.882.5860 - BargerPrecast.com

Date: 2.022018

Drawn By: Eric Barger

7.222024