





### End View

## ASTM C 990 Butyl Sealant

A diagram of a cell membrane cross-section. It shows two phospholipids with grey heads and white tails. There is a gap between them. A small black arrow points from the 'Outside' region into the 'Inside' region through this gap. The word 'Inside' is on the left and 'Outside' is on the right.



### Baffle View

**Tank Warranty:** See Terms & Conditions.

**Centroid(s):** Lid (91, 39), Base (91, 39)

## Weights

**Installation:** The tank hole is not to be more than 18 in. longer and wider than the tank. There shall be a minimum of 6" of 3/4" stone bedding. Do not install across path of vehicles or heavy equipment. This tank is designed for one hundred fifty pounds per square foot (150 lb/ft<sup>2</sup>) uniform loading on the top of the tank with a max backfill cover of 36" and a minimum of 6".

### 3,000 Gallon Grit Tank

### Knoxville Utility Board (KUB) - Knoxville, TN

Date: 5.102010

Drawn By: Eric Barger

Updated: 8.012024