




Top View



Side View




End View




1. (5) Mueller 1" B20045N CC X FIP
2. Mueller Meter Yoke 110B2404R2N
1"x10" Meter Yoke w/Duel
Check
1" H-14223N MP X MIP
1" H-14227N MP X 110C
3. Mueller 1" Insert CTS S28705
4. 1" Type Apex Tubing
5. 29" x 59" Opening Single Leaf
Aluminum Door, Pedestrian Rated
(300 lb/ft²) S1R029059CD
6. 4" Class 56 D.I.P. or 6" Class 56
7. (2) 2" Drain Holes

Component Detail



Pipe detail for taps



Approved for Production

Project: _____

Date: _____

Quantity: _____

By: _____

BARGER PRECAST

Specifications

Concrete: 5,000 psi minimum strength (28 day)

Pipe Penetrations: All pipe penetrations are placed according to job requirements.

5-Gang 1" Meter Vault Pleasant View Utility District

P.O. Box 370 - Kingston TN 37763
Phone 888.882.5860 - BargerPrecast.com

Date: 6.122026

Drawn By: Scott Lee

Approx. Vault Weight: 3,100 lbs.