Top View



Notes

Top weight - 5,500 lb
Bottom weight (empty) - 21,000 lb

48" x72" aluminum hatch

NO STEPS

Side View



Approved for Production

Project: _____ **Date:** _____

Quantity: _____ **By:** _____

BARGER PRECAST

C.R. Barger & Sons, Inc.
P.O. Box 370 - Kingston TN 37763
Phone 888.882.5860 - BargerAndSons.com

Specifications

Concrete: 5,000 psi minimum strength (28 day)
Reinforcing: Primary reinforcement will be a #3 rebar (Grade 60) rebar.
Pipe Penetrations: All pipe penetrations are placed according to job requirements.
Pipe Stands: Adjustable height pipe stands may be provided to support assembly.
Sealant: Sealant used will meet or exceed ASTM C990.
Steps: Aligned under hatch unless specified.
General: Meter vaults are not water tight structures unless specified by Barger And Sons.

9' L x 7' W x 72" T - 8" Fire & Domestic Vault
City of LaVergne

Date:	Drawn By:	Updated:
4.042022	Eric Barger	11.132023